


Tennessee Valley Authority

Thermal Assessment of Existing
161kv & 500kv Transmission Lines

TVA Power Service Area



Why are we gathering aerial laser survey & doing thermal assessments?

- **Before 1977; NESC ground clearance requirements @ 120°F (49°C)**
- **1977 NESC code required clearances at maximum operating temperature**
- **Have generally designed new lines for 100°C since 1977**

Transmission Line Assessment and Up-Rate Program

Background

- NESC Code for Lines Built Before 1977 Required Clearance be Maintained for a Conductor Temperature of 49 Degrees C
- 1977 NESC Code Revision Required Clearances be Maintained Based on Actual Operating Temperatures
- Peak Conditions Typically Require Operation between 80 – 100 Degrees C
- Transmission Line Operation and Clearance Requirements are a Matter of NERC Compliance. The scope includes 8,137 Miles of Transmission Line
 - 2,405 Miles of 500-kV Transmission Lines
 - 5,662 Miles of 161-kV Transmission Lines
 - 70 Miles of 46/69-kV Transmission Lines
- Current Asset Condition Could Impact Reputation and Cost
 - Assumed Rating Could Lead to NERC Reportable Flashover Events
 - Increased Risk of Public Contact Events
 - NESC or NERC Violations Receive More Scrutiny Since Blackout of 2003

**TVA in-house engineering assessed
about 30% of our lines**

**Burns & McDonnell
Mesa Associates
Sargent & Lundy**

**Aerotec LLC
Optimal Geomatics
Geodigital
Network Mapping
Terrapoint USA Inc
Tuck Engineering**

**MESA coupled with Optimal Geomatics
S&L coupled with Geodigital
Burns & Mac and Network Mapping**

Vertical clearance of conductors above roads, driveways, parking lots, areas subject to truck traffic, unpaved land subject to cultivating.

	<u>69kV</u>	<u>161kV</u>	<u>230kV</u>	<u>500kV</u>
TVA	22.1	24.1	25.5	29.8
NESC	19.1	21.1	22.5	26.8
delta	3.0	3.0	3.0	3.0
Lidar NESC + 1 ft.	20.1	22.1	23.5	27.8

- Buffer is 1 ft.
- Need to model as accurate as possible with lidar
- Why?- affects the sag/clearance (long spans could change sag several feet)
- If there is a violation, could be significant cost for modification

Graphical Sag Options



Snap Mode

- Fit to survey point closest to mouse
- Fit to mouse coordinates

Fit Mode

- 1) Ruling Span
Horizontal tension is always the same for all spans in section. Sagging tension and condition will be changed. Display condition will be changed.
 - 2) Finite Element Insulators Plumb at Sagging Condition.
Horizontal tension constant throughout section at sagging condition but may vary at other conditions. Sagging tension will be changed. Display condition will be changed.
 - 3) Finite Element Selected Spans Wire Length Adjustment
Adjust length of wire in selected spans without regard for effects on other spans. Wire lengths for selected spans will be changed. Display condition will be changed.
 - 4) Finite Element All Spans Wire Length Adjustment
Adjust wire length in all spans to fit selected point(s) without changing mid span wire elevation in other spans. Wire length for all spans in section will be changed. Display condition will be changed.
- Tip: There can be a delay after each left click while wire is fit to the selected point(s). Use middle clicks or the Enter key to select points without a fit delay. When done selecting points use a left click to perform the fit.
- 5) Finite Element Manual Length Adjust
Manually enter change in unstressed wire length for a span. Unstressed wire length for selected spans is changed. Display condition will be changed.

6) Finite Element Multiple Point Fit
Calculate catenary constant and required wire & insulator attachment points required to fit through three points in each span. May change wire lengths, structure locations and display condition.

- Adjust wire length in each span to fit calculated catenary and wire attachment points
 - Adjust structure stations, height and offset adjustments to match calculated insulator attachment points
 - Follow up with a Finite Element All Spans Wire Length Adjustment (option 4) after adjustments above
 - Least squares fit to all wire points within specified distance of 3 point catenary curve Max distance from 3 point (ft)
 - Generate report showing attachment point locations and tensions Wire attach. feature
 - Draw markers showing fit results (fit points, catenary curve, attachment points) Insulator attach. feature
 - Create survey points at calculated mid span and wire/insulator attachment points Mid span point feature
- Feature code for structure points (may be used to help refine attachment point calculation)

Automatically select fit points in each span (for fit mode 4 and 6) Feature code for wire fit

- Use single point closest to current wire position (old way)
- Use centroid of all points within 1m of current wire position (tends to err on high side for bundles)
- Use center of rectangle encompassing all points within 1m of current wire position (good for bundles but sensitive to outliers)
- Use lowest of all points within 1m of current wire position (good for bundles but sensitive to outliers)
- Use center of smallest circle enclosing all points within 1 m of current wire (good for bundles but may be sensitive to outliers)
- Use bundle-aware centroid: centroid of each wire's centroids, using points within 1m of current position (less sensitive to outliers)

Enter either the bundle diameter : (in) or the bundle spacing : (in)

[Show Web technical note "Graphical Sag Options: Making the Wire System Match 'As-Built' Survey Points"](#)

With lidar

Structure location ± 0.2 ft

Wire tension ± 20 lbs


Ground/obstacles ± 0.2 ft

However,

Temperature not directly measured.


Derived from IEEE 738

As Captured Match Lidar 110.3deg Creep FE



ion): Section #8, phase 1, 161kV, 'rail acsr 954 45_7', from Str. #74B Set 9 'Mahead' to Str. #E216A Set 4 'MID Back', Section at cond (74B-E216A) 110.3deg 'Creep FE', S=34710.86

212 deg F creep FE




ction #8, phase 1, 161kV, 'rail acsr 954 45_7', from Str. #74B Set 9 'Mahead' to Str. #E216A Set 4 'MID Back', All sections at BARE 212 'Creep FE', S=34927.19


Steps to get FE sag

- Alignment
- Structure locations (station/offset)
- Conductor temperature (weather data)
- Assume sagging temperature (plumb INS)
- As captured least square best fit Tension (FE6)
Used to get tension not move structures
- Adjust each span at mid span (non-plumb INS)FE3

First locate structures (cross section view)



Example of locating structures to match the lidar ghost



Present Location (hgt=4.0 offset 0.0)

Structure Modify [?] [X]

Structure #87
Line angle (deg) 0.00

18body 28leg 2-cond bundle

Station (ft) 34337.75
Height adjust. (ft) 4.00
Offset adjust. (ft) 0.00
Orientation (deg) 0

	Structure Comments
1	87
2	A24 82
3	
4	
5	
-	

	Set Counter
	Weight (lbs)
1	
2	
3	
4	
-	

[Prev] [Next] [View] [Edit] [Material] [Google Earth] [OK] [Cancel]

Adjust Height & Offset (hgt=4.4 offset 0.5)


Structure Modify ? X


Structure #87
Line angle (deg) 0.00

Station (ft)
Height adjust. (ft)
Offset adjust. (ft)
Orientation (deg)

	Structure Comments
1	87
2	A24 82
3	
4	
5	
-	

	Set Counter
	Weight (lbs)
1	
2	
3	
4	
-	





Adjust Station (37337.75 to 37337.4)

Structure Modify [?] [X]

Structure #87
Line angle (deg) 0.00


18body 28leg 2-cond bundle

Station (ft) 34337.40
Height adjust. (ft) 4.50
Offset adjust. (ft) 0.50
Orientation (deg) 0


	Structure Comments
1	87
2	A24 82
3	
4	
5	
-	

	Set Counter
	Weight (lbs)
1	
2	
3	
4	
-	


[Prev] [Next] [View] [Edit] [Material] [Google Earth] [OK] [Cancel]



Example of angle tower



Example of special configuration



2 ft spacing C phase

2' Spacing Ea. Phase

Mid Span Spacer on A & C Phase

FM RR
+34.9

944.9

C-24 68

3'-5 1/2" Angle Bkts.

2-GWDE on Outside of Angle

1 Damper Per Cond. (H & B)

2' Spacing on C Phase

4 1/2" Bit RR
1KV Temp. Line

915.1

469 KX TL

469 KX TL


6 + 50

Mid Span Spacer on A & C Phase

A-24 88

1 Damper Per Cond. (Back)

0



I.D. 599
SING. STRING SUSP.
ASSEMBLY

Use on Teno. Bkts., 2 Angle Bkts.
 & 3-5 1/2" Angle Bkts.

* Use Only When Specified on P&P

11-2-11


*



(2)

BILL OF MATERIAL


ITEM NO.	DESCRIPTION		Susp.	S.S.	Clamp	Special	Passer	D.E.
1	5 3/8" x 10" Disc. Insulator 25,000*	26.015	10	20	22	28		
2	"Y" Type Bell Clevis with (Bolt Nut & Cotter)	54.032-9	1		1	2		
**	3 Susp. Clamp with Socket Eye (Special)	BT-9508U	1					
**	4 Susp. Clamp (Special)	BT-9548U	1	2				
5	5/8" Eye to Eye Extension Rod (13")		2	2				
*	6 7/8" Eye to Eye Extension Rod (24" or 34")		2*	2*				



IMG00034.jpg
Type: JPG File
Size: 1.80 MB
Dimension: 2592 x 1944 pixels





2ft conductor spacing C phase




Example of As built not on Drawing

str 154 no special conductor spacing





mid cond 24" spacing
NOT ON P&P



Graphical Sag Options

Snap Mode

Fit to survey point closest to mouse

Fit to mouse coordinates

Fit Mode

1) Ruling Span

Horizontal tension is always the same for all spans in section.
Sagging tension and condition will be changed. Display condition will be changed.

2) Finite Element Insulators Plumb at Sagging Condition.

Horizontal tension constant throughout section at sagging condition but may vary at other conditions.
Sagging tension will be changed. Display condition will be changed.

3) Finite Element Selected Spans Wire Length Adjustment

Adjust length of wire in selected spans without regard for effects on other spans.
Wire lengths for selected spans will be changed. Display condition will be changed.

4) Finite Element All Spans Wire Length Adjustment

Adjust wire length in all spans to fit selected point(s) without changing mid span wire elevation in other spans.
Wire length for all spans in section will be changed. Display condition will be changed.

Tip: There can be a delay after each left click while wire is fit to the selected point(s). Use middle clicks or the Enter key to select points without a fit delay. When done selecting points use a left click to perform the fit.

5) Finite Element Manual Length Adjust

Manually enter change in unstressed wire length for a span.
Unstressed wire length for selected spans is changed. Display condition will be changed.

6) Finite Element Multiple Point Fit

Calculate catenary constant and required wire & insulator attachment points required to fit through three points in each span.
May change wire lengths, structure locations and display condition.

Adjust wire length in each span to fit calculated catenary and wire attachment points

Adjust structure stations, height and offset adjustments to match calculated insulator attachment points

Follow up with a Finite Element All Spans Wire Length Adjustment (option 4) after adjustments above

Least squares fit to all wire points within specified distance of 3 point catenary curve

Max distance from 3 point (ft) 3.000

Generate report showing attachment point locations and tensions

Wire attach. feature 1702 cond mid FE6

Draw markers showing fit results (fit points, catenary curve, attachment points)

Insulator attach. feature 1702 cond mid FE6

Create survey points at calculated mid span and wire/insulator attachment points

Mid span point feature 1702 cond mid FE6

Feature code for structure points (may be used to help refine attachment point calculation)

99999 Substation Data

Automatically select fit points in each span (for fit mode 4 and 6)

Feature code for wire fit

1701 Conductor (OH)-Transmis:

Use single point closest to current wire position (old way)

Use centroid of all points within 1m of current wire position (tends to err on high side for bundles)

Use center of rectangle encompassing all points within 1m of current wire position (good for bundles but sensitive to outliers)

Use lowest of all points within 1m of current wire position (good for bundles but sensitive to outliers)

Use center of smallest circle enclosing all points within 1 m of current wire (good for bundles but may be sensitive to outliers)

Use bundle-aware centroid: centroid of each wire's centroids, using points within 1m of current position (less sensitive to outliers)

Enter either the bundle diameter : (in) 13.000 or the bundle spacing : (in) 13.000

Show Web technical note "Graphical Sag Options: Making the Wire System Match 'As-Built' Survey Points"

OK

Cancel

Before you can do graphical sag you must determine as capture conductor temperature

IEEE Std 738-2006 Steady-State Conductor Temperature



THERMAL CALCULATIONS METHOD

IEEE Standard 738-2006

CIGRE Brochure 207

SOLAR HEATING DATA

Day of Year

Use day of year producing maximum solar heating

Use specified day of year

Line Direction

Line perpendicular to solar azimuth (maximum solar heating)

Use specified line azimuth (deg)

Latitude (deg)

Sun time (10=10am, 14=2pm, 99= no sun)

Atmosphere

WEATHER DATA

Air temperature (deg F)

Wind Speed (ft/s)

Wind to conductor angle (0=parallel) (deg)

Conductor elevation (ft)

CONDUCTOR DATA

Cable file name

CALCULATION DATA

Steady-state ac current (Amps)


Provide a name for the graph:

OK


Cancel

Tennessee Valley Authority, Project: "colbert-oakland cwa.xyz"
PLS-CADD Version 10.002, 1:39:15 PM Monday, July 06, 2009
Line Title: 'tower'

Flight Time
5/01/2005
17:09CDT-17:59CDT



For Example,
From the weather data
Str 124-Colbert 17:56-17:59 CDT



	GMT	CDT	deg C	m/s		
Date	Time		Temp Out	Wind Speed	Wind Dir	
-----	-----		-----	-----	-----	
01/05/2005	22:51	5:51 PM	18.9	1.3	NNW	337.5
01/05/2005	22:52	5:52 PM	18.9	0.9	W	270
01/05/2005	22:53	5:53 PM	18.9	1.3	W	270
01/05/2005	22:54	5:54 PM	19.1	0.9	W	270
01/05/2005	22:55	5:55 PM	19.1	1.8	WSW	247.5
01/05/2005	22:56	5:56 PM	18.9	2.2	WNW	292.5
01/05/2005	22:57	5:57 PM	18.9	3.1	WNW	292.5
01/05/2005	22:58	5:58 PM	18.9	1.3	NW	315
01/05/2005	22:59	5:59 PM	18.9	1.3	NW	315
01/05/2005	23:00	6:00 PM	18.9	1.8	NNE	382.5
01/05/2005	23:01	6:01 PM	18.9	1.3	W	270
01/05/2005	23:02	6:02 PM	18.9	0.9	N	360
01/05/2005	23:03	6:03 PM	18.9	2.2	NW	315
01/05/2005	23:04	6:04 PM	18.9	2.2	WSW	247.5
			ave	ave		
			18.9	1.61		
			deg F	ft/s		ave
			66.1	5.27		298.93
					max	382.5
						83.57
					min	247.5
						51.43

Not use 22.5

Average about WNW

Use average for flight time +/- 5min

Temp not variable but wind speed and direction are


Easting & Northing from PI report gives Azimuth


Convert Flight Time to Sun Time

Using difference between Azimuth and wind direction gives wind angle, for example from str 124 to Colbert AZ=59deg Wind Dir = 298.9deg


121		05/01/2005										
STR #	STR TYPE	EASTING	NORTHING	FLIGHT TIME	SUN TIME	AVERAGE SUN TIME	AZIMUTH (MATCH) (PLS)	TEMP (°F)	WIND (fps)	WIND DIRECTION (DEG)	WIND ANGLE	USE WIND ANGLE
Oakland	PULL-OFF	1884910.98	1768918.28	17:09 CDT	16.3446	16.35	96	66.9	8.67	296.3	19.8	45
66	H20 80	1885455.9	1768856.85	17:10 CDT	16.3613	16.42	314	66.7	8.88	303.8	10.7	30
74	H20 56	1880219.14	1773986.5	17:17 CDT	16.4780	16.49	220	66.5	8.10	308.1	88.0	90
77	H20 72	1878180.74	1771560.55	17:19 CDT	16.5113	16.59	191	66.5	8.26	313.9	57.1	75
89	H20 60	1875709.96	1758881.66	17:29 CDT	16.6780	16.70	183	66.4	8.65	308.6	54.3	75
93	G20 68	1875515.79	1754977.75	17:32 CDT	16.7280	16.83	199	66.3	8.19	301.3	77.5	90
109	G20 84	1869634.3	1737708.284	17:44 CDT	16.9280	16.95	216	66.1	6.56	303.8	87.7	90
112/72	G20 76	1867851.79	1735256.66	17:47 CDT	16.9780	16.99	228	66.2	5.93	296.0	68.1	90
115/69	M21 80	1865148.42	1732812.296	17:49 CDT	17.0113	17.03	228	66.2	5.70	289.0	61.2	90
118/66	M21 80	1860347.73	1728470.06	17:51 CDT	17.0446	17.05	211	66.2	6.53	283.1	72.4	90
119/65	H20 92	1859934.45	1727774.05	17:52 CDT	17.0613	17.09	149	66.1	6.21	295.7	33.7	60
122/62	H20 92	1861123.3	1725760.41	17:55 CDT	17.1113	17.11	140	66.1	5.40	296.6	23.6	45
123/61	H20 92	1861703.3	1725065.52	17:55 CDT	17.1113	17.12	55	66.1	5.30	294.4	59.4	75
124	H20 60	1862397.32	1725552.74	17:56 CDT	17.1280	17.15	59	66.1	5.27	298.9	60.1	75
Colbert	Pulloff	1862890.59	1725850.63	17:59 CDT	17.1780							

Conductor Bearing
59deg





To Demonstrate Graphically
 Using F7 (measure) azi 298.9
 line shows angle between conductor & wind
 Angle = 60.1deg
 But from the weather data variance in wind
 direction +/-
 Therefore, use 75deg (more cooling)



Weather instruments:

Multiple Davis Instruments Weather Wizard III portable weather stations with recording equipment in vinyl container and with weather probes mounted on telescopic masts.

Temperature accuracy: +/- 1 degree F

Temperature range: -50 degrees F to 140 degrees F

Wind speed accuracy: +/- 5%

Wind speed range: 2 mph to 150 mph (2.9 ft/sec to 220 ft/sec)

Wind direction accuracy: +/- 7 degrees

$$LST = CT + \left(\frac{1}{15}\right)(L_{std} - L_{loc}) + E - DT \quad [\text{hr}] \quad \text{Equation 2}$$

Equation for Sun Time

Where:

LST = Local Solar Time [hr]

CT = Clock Time [hr]

L_{std} = Standard Meridian for the local time zone [degrees west]

L_{loc} = Longitude of actual location [degrees west]

E = Equation of Time [hr]

DT = Daylight Savings Time correction (DT = 0 if not on Daylight Savings Time, otherwise DT is equal to the number of hours that the time is advanced for Daylight Savings Time, usually 1hr)

In using Equation 2, all of the times must first be converted to decimal format from zero to 24, (e.g., a clock time of 3:45 p.m. is expressed as CT = 15.75 hr).

Values of the Equation of Time, E, are calculated by:

$$E = 0.165 \sin 2B - 0.126 \cos B - 0.025 \sin B \quad [\text{hr}] \quad \text{Equation 3a}$$

where:
$$B = \frac{360(n - 81)}{364} \quad [\text{degrees}]$$

and n is the day of the year.

```
=CT+(1/15)*(IF(OR(C8="CST",C8="CDT"),90,IF(OR(C8="EST",C8="EDT"),75,"Check"))-A8)+(0.165*SIN(2*RADIANS(360*(n-81)/364))-0.126*COS(RADIANS(360*(n-81)/364))-0.025*SIN(RADIANS(360*(n-81)/364)))-IF(OR(C8="CST",C8="EST"),0,IF(OR(C8="CDT",C8="EDT"),1,"Check"))
```

Equation in EXCEL

Also, use website

- <http://aa.usno.navy.mil>

U.S. Naval Observatory
Astronomical Applications Department

Sun and Moon Data for One Day

The following information is provided for Sheffield, Colbert County, Alabama (longitude W87.7, latitude N34.8):

	Sunday 1 May 2005	Central Daylight Time
	SUN	
	Begin civil twilight	5:33 a.m.
	Sunrise	6:00 a.m.
	Sun transit	12:48 p.m.
	Sunset	7:36 p.m.
	End civil twilight	8:03 p.m.
	MOON	
day	Moonset	11:26 a.m. on preceding
	Moonrise	2:22 a.m.
	Moon transit	7:27 a.m.
	Moonset	12:39 p.m.
day	Moonrise	2:59 a.m. on following

-48/60 = -0.80 17:59 =17.98 -0.80 = 17.18 (matches spreadsheet)

IEEE Std. 738-2006 method of calculation

Air temperature is 66.10 (deg F)

Wind speed is 5.27 (ft/s)

Angle between wind and conductor is 75 (deg)

Conductor elevation above sea level is 506 (ft)

Conductor bearing is 59 (deg) (user specified bearing, may not be value producing maximum solar heating)

Sun time is 17.15 hours (solar altitude is 19 deg. and solar azimuth is -85 deg.)

Conductor latitude is 34.8 (deg)

Atmosphere is **CLEAR**

Day of year is 121 (corresponds to May 1 in year 2009) (user specified day, may not be day producing maximum solar heating)

Conductor description: 795 kcmil 26/7 Strands DRAKE ACSR - Adapted from 1970's Publicly Available Data

Conductor diameter is 1.108 (in)

Conductor resistance is 0.1166 (Ohm/mile) at 77.0 (deg F)

and 0.1390 (Ohm/mile) at 167.0 (deg F)

Emissivity is 0.7 and solar absorptivity is 0.9

Solar heat input is 3.396 (Watt/ft) (corresponds to Global Solar Radiation of **40.865** (Watt/ft²) - which was calculated)

Radiation cooling is 0.514 (Watt/ft)

Convective cooling is 3.190 (Watt/ft)

Given a constant ac current of 118.5 amperes,
The conductor surface temperature is **74.6 (deg F)**

Surface? Change in PLS 10.002

Range Ambient 66.1 to Only Uncertain Variable No Wind 90.7 previous 74.6

IEEE Std. 738-2006 method of calculation

Lower Bound Ambient too Conservative
Upper Bound No wind not realistic 2fps min

Air temperature is 66.10 (deg F)

Wind speed is 0.00 (ft/s)

Angle between wind and conductor is 75 (deg)

Conductor elevation above sea level is 506 (ft)

Conductor bearing is 59 (deg) (user specified bearing, may not be value producing maximum solar heating)

Sun time is 17.15 hours (solar altitude is 19 deg. and solar azimuth is -85 deg.)

Conductor latitude is 34.8 (deg)

Atmosphere is CLEAR

Day of year is 121 (corresponds to May 1 in year 2009) (user specified day, may not be day producing maximum solar heating)

Conductor description: 795 kcmil 26/7 Strands DRAKE ACSR - Adapted from 1970's Publicly Available Data

Conductor diameter is 1.108 (in)

Conductor resistance is 0.1166 (Ohm/mile) at 77.0 (deg F)

and 0.1390 (Ohm/mile) at 167.0 (deg F)

Emissivity is 0.7 and solar absorptivity is 0.9

Solar heat input is 3.396 (Watt/ft) (corresponds to Global Solar Radiation of 40.865 (Watt/ft²) - which was calculated)

Radiation cooling is 1.559 (Watt/ft)

Convective cooling is 2.157 (Watt/ft)

Given a constant ac current of 118.5 amperes,

The conductor surface temperature is 90.7 (deg F)

IEEE Std 738-2006 Steady-State Conductor Temperature



THERMAL CALCULATIONS METHOD

IEEE Standard 738-2006

CIGRE Brochure 207

SOLAR HEATING DATA

Day of Year

Use day of year producing maximum solar heating

Use specified day of year

Line Direction

Line perpendicular to solar azimuth (maximum solar heating)

Use specified line azimuth (deg)

Latitude (deg)

Sun time (10=10am, 14=2pm, 99= no sun)

Atmosphere

WEATHER DATA

Air temperature (deg F)

Wind Speed (ft/s)

Wind to conductor angle (0=parallel) (deg)

Conductor elevation (ft)

CONDUCTOR DATA

Cable file name

Clear is clean air and industrial is dirty air, Particulates increase conductivity

CALCULATION DATA

Steady-state ac current (Amps)

Provide a name for the graph:

OK

Cancel

Sky Not Always Clear

History : Weather Underground

Time: (CDT)	Temp.:	DewPoint:	Humidity:	Sea Level: Pressure	Visibility:	WindDir:Wind: SpeedSpeed:	Precip:	Events:Conditions:
8:53 AM	53.1 °F	41.0 °F	64%	30.20 in	10.0 miles	Calm Calm - N/A		Clear
9:53 AM	59.0 °F	37.0 °F	44%	30.21 in	10.0 miles	Calm Calm - N/A		Clear
10:53 AM	61.0 °F	33.1 °F	35%	30.21 in	10.0 miles	WNW 9.2 mph - N/A		Clear
11:53 AM	63.0 °F	33.1 °F	33%	30.21 in	10.0 miles	WNW 10.4 mph	16.1 mph	N/A Clear
12:53 PM	64.0 °F	34.0 °F	33%	30.18 in	10.0 miles	Variable 6.9 mph - N/A		Clear
1:53 PM	64.0 °F	35.1 °F	34%	30.17 in	10.0 miles	Variable 4.6 mph - N/A		Partly Cloudy
2:53 PM	64.9 °F	37.0 °F	36%	30.16 in	10.0 miles	Variable 4.6 mph - N/A		Clear
3:53 PM	66.0 °F	39.0 °F	37%	30.14 in	10.0 miles	WNW 6.9 mph - N/A		ScatteredClouds
4:53 PM	66.0 °F	37.0 °F	34%	30.13 in	10.0 miles	WNW 13.8 mph - N/A		Partly Cloudy
5:53 PM	6.0 °F	36.0 °F	33%	30.12 in	10.0 miles	NW 10.4 mph - N/A		Clear
6:53 PM	63.0 °F	35.1 °F	35%	30.12 in	10.0 miles	NW 6.9 mph - N/A		Clear
7:53 PM	55.9 °F	39.9 °F	55%	30.12 in	10.0 miles	Calm Calm - N/A		Clear
8:53 PM	51.1 °F	43.0 °F	74%	30.12 in	10.0 miles	South 3.5 mph - N/A		Partly Cloudy
9:53 PM	48.0 °F	43.0 °F	83%	30.13 in	10.0 miles	SSW 3.5 mph - N/A		Partly Cloudy
10:53 PM	46.0 °F	41.0 °F	83%	30.14 in	10.0 miles	Calm Calm - N/A		Clear
11:53 PM	45.0 °F	42.1 °F	90%	30.14 in	10.0 miles	Calm Calm - N/A		Clear

	GMT	CDT	deg C	m/s		Watts/m ²	Watts/ft ²			
Date	Time		Temp Out	Wind Speed	Wind Dir	Solar Rad.		Drake 795	26/7	
-----	-----		-----	-----	-----	-----		dia		
01/05/2005	22:51	5:51 PM	18.9	1.3	NNW	337.5	275	25.55	1.108	2.359
01/05/2005	22:52	5:52 PM	18.9	0.9	W	270	271	25.18	1.108	2.325
01/05/2005	22:53	5:53 PM	18.9	1.3	W	270	262	24.34	1.108	2.247
01/05/2005	22:54	5:54 PM	19.1	0.9	W	270	243	22.58	1.108	2.084
01/05/2005	22:55	5:55 PM	19.1	1.8	WSW	247.5	257	23.88	1.108	2.205
01/05/2005	22:56	5:56 PM	18.9	2.2	WNW	292.5	251	23.32	1.108	2.153
01/05/2005	22:57	5:57 PM	18.9	3.1	WNW	292.5	250	23.23	1.108	2.145
01/05/2005	22:58	5:58 PM	18.9	1.3	NW	315	248	23.04	1.108	2.127
01/05/2005	22:59	5:59 PM	18.9	1.3	NW	315	245	22.76	1.108	2.102
01/05/2005	23:00	6:00 PM	18.9	1.8	NNE	382.5	243	22.58	1.108	2.084
01/05/2005	23:01	6:01 PM	18.9	1.3	W	270	239	22.20	1.108	2.050
01/05/2005	23:02	6:02 PM	18.9	0.9	N	360	236	21.93	1.108	2.024
01/05/2005	23:03	6:03 PM	18.9	2.2	NW	315	232	21.55	1.108	1.990
01/05/2005	23:04	6:04 PM	18.9	2.2	WSW	247.5	225	20.90	1.108	1.930
			ave	ave				ave		
			18.9	1.61				23.073		2.130
			deg F	ft/s		ave				
			66.1	5.27		298.93				
					max	382.5	NNE			
						83.57				
Use average for flight time +- 5min										
					min	247.5	WSW			
						51.43				

NOT ALL WEATHER
DATA REPORTS
GAVE SOLAR
RADIATION

IEEE Std. 738-2006 method of calculation

Air temperature is 66.10 (deg F)

Wind speed is 5.27 (ft/s)

Angle between wind and conductor is 75 (deg)

Conductor elevation above sea level is 506 (ft)

Conductor bearing is 59 (deg) (user specified bearing, may not be value producing maximum solar heating)

Sun time is **18.063** hours (solar altitude is 8 deg. and solar azimuth is -77 deg.)

Conductor latitude is 34.8 (deg)

Atmosphere is CLEAR

Day of year is 121 (corresponds to May 1 in year 2009) (user specified day, may not be day producing maximum solar heating)

Conductor description: 795 kcmil 26/7 Strands DRAKE ACSR - Adapted from 1970's Publicly Available Data

Conductor diameter is 1.108 (in)

Conductor resistance is 0.1166 (Ohm/mile) at 77.0 (deg F)

and 0.1390 (Ohm/mile) at 167.0 (deg F)

Emissivity is 0.7 and solar absorptivity is 0.9

Solar heat input is 1.918 (Watt/ft) (corresponds to Global Solar Radiation of **23.081** (Watt/ft²) - which was calculated)

Radiation cooling is 0.306 (Watt/ft)

Convective cooling is 1.919 (Watt/ft)

Given a constant ac current of 118.5 amperes,

The conductor surface temperature is 71.2 (deg F)

Iterate on Sun time
to get Watts/ft² to
match

Changed conductor
temp from 74.6 to 71.2
(Very Cloudy would be
significant)

Steps to get FE sag

- Alignment
- Structure locations (station/offset)
- Conductor temperature (weather data)
- Assume sagging temperature (plumb INS)
- As captured least square best fit Tension (FE6)
Used to get tension not move structures
- Adjust each span at mid span (non-plumb INS)FE3

Assumed stringing condition 60deg Initial insulators plumb

Section Modify [?] [X]

Section 9 from structure #74B to structure #E216A

Type:

Voltage (kV): Conductors per phase:

Sagging

Override calculated ruling span

Ruling Span (ft): Condition: Temperature (deg F):

Catenary (ft): Horiz. Tension (lbs):

Display

Show selected weather case

W/C: Wind from:

Condition: Phase:

CRI Notes: TVA Single Circuit

Displayed Phase, Displayed Weather-Case/Catenary will not take effect until override in Section/Display-Options is disabled.

SAPS Finite Element Sag-Tension Options

Clip Insulators (lock unstressed length, force finite element sag-tension)

Sagging Tension is derived from least square best fit of As Captured

As Captured Temp

Least Square Best Fit

- FE gives a different tension in each span
- FE gives insulator swing at every condition besides Sagging Condition
- Thus, FE gives insulator swings at As Captured Temperature
- Must determine if swing/sag is due to FE or insulator installed out of plumb initially
- Input Sagging condition Tension(60deg Initial) is one value
- Determine outliers (spans that do not match FE tension)

Section Modify [?] [X]

Section 8 from structure #74B to structure #E216A

Type:

Voltage (kV): Conductors per phase:

Sagging

Override calculated ruling span

Ruling Span (ft): Condition:

Temperature (deg F): Catenary (ft):

Horiz. Tension (lbs):

Display

Show selected weather case

WC: Wind from:

Condition: Phase:

CRI Notes: TVA Single Circuit


Displayed Phase will not take effect until override in Section/Display-Options is disabled.

SAPS Finite Element Sag-Tension Options

Clip Insulators (lock unstressed length, force finite element sag-tension)

To Illustrate
Using Sagging Tension
= 6000

Note: str are adjusted



Least Square Best Fit

6) Finite Element Multiple Point Fit
Calculate catenary constant and required wire & insulator attachment points required to fit through three points in each span.
May change wire lengths, structure locations and display condition.

Adjust wire length in each span to fit calculated catenary and wire attachment points

Adjust structure stations, height and offset adjustments to match calculated insulator attachment points

Follow up with a Finite Element All Spans Wire Length Adjustment (option 4) after adjustments above

Least squares fit to all wire points within specified distance of 3 point catenary curve Max distance from 3 point (ft)

Generate report showing attachment point locations and tensions

Draw markers showing fit results (fit points, catenary curve, attachment points)

Create survey points at calculated mid span and wire/insulator attachment points

Wire attach. feature ▼

Insulator attach. feature ▼

Mid span point feature ▼

Feature code for structure points (may be used to help refine attachment point calculation) ▼

Automatically select fit points in each span (for fit mode 4 and 6) Feature code for wire fit ▼

Use single point closest to current wire position (old way)

Use centroid of all points within 1m of current wire position (tends to err on high side for bundles)

Use center of rectangle encompassing all points within 1m of current wire position (good for bundles but sensitive to outliers)

Use lowest of all points within 1m of current wire position (good for bundles but sensitive to outliers)

Use center of smallest circle enclosing all points within 1 m of current wire (good for bundles but may be sensitive to outliers)

Use bundle-aware centroid: centroid of each wire's centroids, using points within 1m of current position (less sensitive to outliers)

Enter either the bundle diameter : (in) or the bundle spacing : (in)

[Show Web technical note "Graphical Sag Options: Making the Wire System Match 'As-Built' Survey Points"](#)

Least Square Answers do not change with Sagging input

Based on lidar points only

Graphical Sag Tension Report

Structure Number	Set Number	Phase No.	Three Point Calc. Tension (lbs)	Least Squares Calc. Tension (lbs)	Number Points Least Squares Fit	Tension Before (lbs)	Tension After (lbs)	Tension Error -Tension Before (lbs)
74B	9	1	2124.17	2991.69	225	4891.16	6005.32	3013.63
75	4	1	4927.85	4907.70	2031	4906.58	6005.56	1097.87
76	4	1	4954.27	4937.14	1826	4887.36	6007.43	1070.29
77	4	1	4970.02	4959.16	1520	4907.58	6004.48	1045.32
78	4	1	4970.25	5007.41	1151	4951.95	6002.76	995.35
79	4	1	4971.11	5024.33	1126	4955.94	6002.20	977.88
80	4	1	4936.19	5041.59	816	5004.34	6002.03	960.44
81	4	1	5102.22	5106.94	1335	5108.82	6002.31	895.38
82	4	1	4859.67	4973.88	865	5030.29	6003.36	1029.48
83	4	1	5017.29	5036.29	1506	4989.98	6005.95	969.66
84	4	1	5039.66	5034.95	1211	4959.21	6006.30	971.34
85	4	1	4966.74	5020.04	986	4956.82	6004.68	984.64
86	4	1	4997.25	5063.62	818	4928.81	6004.25	940.62
87	4	1	5042.49	5017.46	914	4924.90	6004.65	987.18
88	4	1	4969.19	4972.16	901	4887.46	6006.45	1034.30
89	4	1	5035.10	4950.09	1133	4830.23	6007.69	1057.59
90	4	1	4806.83	4861.13	1311	4768.40	6008.11	1146.98
91	4	1	4839.69	4870.14	1057	4743.14	6009.36	1139.22
92	4	1	4770.34	4901.51	780	4724.05	6012.02	1110.51
93	4	1	4838.02	4856.39	820	4700.56	6011.30	1154.91
94	4	1	4768.98	4875.28	822	4699.75	6009.28	1134.00

Row #	Structure	Set Number	Phase No.	Three Point Calc. Tension (lbs)	Least Squares Calc. Tension (lbs)	Number Points Least Squares Fit	Tension Before (lbs)	Difference	red > 6%	2%	4%	6%
1	74B	9	1	2124.17	2991.69	225	5010.5	-2018.81	-67.5%			
2	75	4	1	4935.39	4907.7	2031	5026.01	-118.31	-2.4%		-118.31	-118.31
3	76	4	1	4954.27	4937.14	1826	5007.54	-70.4	-1.4%	-70.4	-70.4	-70.4
4	77	4	1	4970.02	4959.16	1520	5028.11	-68.95	-1.4%	-68.95	-68.95	-68.95
5	78	4	1	4970.25	5007.41	1151	5073.33	-65.92	-1.3%	-65.92	-65.92	-65.92
6	79	4	1	5093.06	5024.33	1126	5078.41	-54.08	-1.1%	-54.08	-54.08	-54.08
7	80	4	1	4936.19	5041.59	816	5128.46	-86.87	-1.7%	-86.87	-86.87	-86.87
8	81	4	1	5072.87	5106.94	1335	5235.8	-128.86	-2.5%		-128.86	-128.86
32	105	4	1	4867.77	4894.13	687	4922.5	-28.37	-0.6%	-28.37	-28.37	-28.37
33	106	4	1	4864.78	4868.29	571	4909.3	-41.01	-0.8%	-41.01	-41.01	-41.01

Section Modify

Section 8 from structure #74B to structure #E216A

Type:

Voltage (kV): Conductors per phase:

Sagging

Override calculated ruling span

Ruling Span (ft):

Condition: Temperature (deg F): Catenary (ft): Horiz. Tension (lbs):

Display

Show selected weather case

WC: Wind from: Condition: Phase:

CRI Notes: TVA Single Circuit


Displayed Phase will not take effect until override in Section/Display-Options is disabled.

SAPS Finite Element Sag-Tension Options

Clip Insulators (lock unstressed length, force finite element sag-tension)

2.84	593	4922.23	-49.39	-1.0%	-49.39	-49.39	-49.39
89.5	633	4843.75	-54.25	-1.1%	-54.25	-54.25	-54.25
2.08	745	4860.05	2.03	0.0%	2.03	2.03	2.03
61.2	1077	4871.71	89.49	1.8%	89.49	89.49	89.49
2.36	1498	4873.31	199.05	3.9%		199.05	199.05
6.26	1162	4939.82	216.44	4.2%			216.44
0.98	684	4991.43	159.55	3.1%		159.55	159.55
5.32	747	5078.04	97.28	1.9%	97.28	97.28	97.28
3.59	657	4911.14	52.45	1.1%	52.45	52.45	52.45
9.84	521	4884.42	55.42	1.1%	55.42	55.42	55.42
2.26	594	4900.73	232.53	4.5%			232.53
9.92	618	4941.22	198.7	3.9%		198.7	198.7
1.57	1029	4996.46	145.11	2.8%		145.11	145.11
0.71	1037	5069.7	101.01	2.0%	101.01	101.01	101.01
9.45	399	4942.17	-272.72	-5.8%			-272.72
			-1754.58		-739.25	287.62	264.23
			143		115	138	142
					0.80	0.97	0.99
			-12.26979		-6.42826	2.084203	1.860775

Stringing condition 60deg Initial Assumed insulators plumb (to be corrected)



Before Adjustments


Wire Lengths and Attachment Stiffness

The data below applies only to finite element sag-tension (not ruling span). Unstressed lengths are at 0 de
Stiffnesses below are for level 2 SAPS analysis and also for level 3 analysis of structures not modeled with
For level 3 SAPS analysis with PLS-POLE or TOWER structures attachment stiffnesses will be determined
Light blue columns used to define optional concentrated loads (marker balls, spacer-dampers...)
Unstressed lengths are calculated prior to the addition of concentrated loads (concentrated loads assume


Sagging condition: Initial RS

	Structure Number	Set Number	Phase Number	Structure Attachment Transverse Stiffness (lbs/ft)	Structure Attachment Longitudinal Stiffness (lbs/ft)	#1 Load Point Span Fraction
1	74B	10	1	NA	NA	
2	75	5	1	Default	Default	
3	76	3	1	Default	Default	
4	77	3	1	Default	Default	
5	78	5	1	Default	Default	
6	79	5	1	Default	Default	
7	80	5	1	Default	Default	
8	81	5	1	Default	Default	
9	82	5	1	Default	Default	
10	83	5	1	Default	Default	
11	84	5	1	Default	Default	
12	85	5	1	Default	Default	
13	86	5	1	Default	Default	

As captured temperature no adjustment



As captured temperature no adjustment



Graphical Sag Options



Snap Mode

- Fit to survey point closest to mouse Fit to mouse coordinates

Fit Mode

- 1) Ruling Span
Horizontal tension is always the same for all spans in section.
Sagging tension and condition will be changed. Display condition will be changed.
- 2) Finite Element Insulators Plumb at Sagging Condition.
Horizontal tension constant throughout section at sagging condition but may vary at other conditions.
Sagging tension will be changed. Display condition will be changed.
- 3) Finite Element Selected Spans Wire Length Adjustment
Adjust length of wire in selected spans without regard for effects on other spans.
Wire lengths for selected spans will be changed. Display condition will be changed.
- 4) Finite Element All Spans Wire Length Adjustment
Adjust wire length in all spans to fit selected point(s) without changing mid span wire elevation in other spans.
Wire length for all spans in section will be changed. Display condition will be changed.
- Tip: There can be a delay after each left click while wire is fit to the selected point(s). Use middle clicks or the Enter key to select points without a fit delay. When done selecting points use a left click to perform the fit.
- 5) Finite Element Manual Length Adjust
Manually enter change in unstressed wire length for a span.
Unstressed wire length for selected spans is changed. Display condition will be changed.

- 6) Finite Element Multiple Point Fit
Calculate catenary constant and required wire & insulator attachment points required to fit through three points in each span.
May change wire lengths, structure locations and display condition.

- Adjust wire length in each span to fit calculated catenary and wire attachment points
- Adjust structure stations, height and offset adjustments to match calculated insulator attachment points
- Follow up with a Finite Element All Spans Wire Length Adjustment (option 4) after adjustments above
- Least squares fit to all wire points within specified distance of 3 point catenary curve Max distance from 3 point (ft) 3.000
- Generate report showing attachment point locations and tensions Wire attach. feature 1702 cond mid FE6 ▾
- Draw markers showing fit results (fit points, catenary curve, attachment points) Insulator attach. feature 1702 cond mid FE6 ▾
- Create survey points at calculated mid span and wire/insulator attachment points Mid span point feature 1702 cond mid FE6 ▾

Feature code for structure points (may be used to help refine attachment point calculation) 99999 Substation Data ▾

- Automatically select fit points in each span (for fit mode 4 and 6) Feature code for wire fit 1702 cond mid FE6 ▾

- Use single point closest to current wire position (old way)
- Use centroid of all points within 1m of current wire position (tends to err on high side for bundles)
- Use center of rectangle encompassing all points within 1m of current wire position (good for bundles but sensitive to outliers)
- Use lowest of all points within 1m of current wire position (good for bundles but sensitive to outliers)
- Use center of smallest circle enclosing all points within 1 m of current wire (good for bundles but may be sensitive to outliers)
- Use bundle-aware centroid: centroid of each wire's centroids, using points within 1m of current position (less sensitive to outliers)


Enter either the bundle diameter : (in) 13.000 or the bundle spacing : (in) 13.000

[Show Web technical note "Graphical Sag Options: Making the Wire System Match 'As-Built' Survey Points"](#)

OK


Cancel

All phases As captured temperature with adjustment




phase 1, 161kV, 'rail acsr 954 45_7', from Str. #74B Set 9 'Mahead' to Str. #E216A Set 4 'MID Back', Section at cond (74B-E216A) 110.3deg 'Creep FE', S=

Center phase As captured temperature with adjustment



As captured temperature with adjustment



After Adjustments


Wire Lengths and Attachment Stiffness

The data below applies only to finite element sag-tension (not ruling span). Unstressed lengths and attachment stiffnesses below are for level 2 SAPS analysis and also for level 3 analysis of structures not using PLS-POLE or TOWER. For level 3 SAPS analysis with PLS-POLE or TOWER structures attachment stiffnesses will be zero. Light blue columns used to define optional concentrated loads (marker balls, spacer-dampers, etc.). Unstressed lengths are calculated prior to the addition of concentrated loads (concentrated loads are added after the sag-tension analysis).


Sagging condition: Initial RS

	Structure Number	Set Number	Phase Number	Ahead Span Unstressed Length (ft)	Ahead Span Unstressed Length Change (ft)	Structure Attachment Transverse Stiffness (lbs/in)
1	74B	10	1	96.983	0.000	
2	75	5	1	1324.902	0.602	
3	76	3	1	1030.835	-0.496	
4	77	3	1	1216.563	0.486	
5	78	5	1	1373.415	0.090	
6	79	5	1	1171.375	-0.001	
7	80	5	1	1262.355	0.080	
8	81	5	1	1803.991	0.953	
9	82	5	1	1160.212	0.520	
10	83	5	1	1292.692	-0.220	
11	84	5	1	1182.843	0.552	
12	85	5	1	1360.806	-0.432	

Stringing condition 60deg Initial with adjustments (Assumption of plumb Insulator removed)



Angle brackets 3'-5"



Brackets do not swing with Level 2

SAPS Finite Element Sag-Tension [?] [X]

SAPS Analysis Level

Selection below will affect type of model used when doing finite element sag-tension.

L2 Finite element analysis of single section (no interaction between sections)
(sag-tension will take longer than for ruling span but still reasonably responsive)

L3 Finite element analysis of system of sections interconnected by stiffness matrices
(sag-tension computations will generally take a few seconds and use lots of RAM)

Level 3 options

Limit level 3 modeling to PLS-POLE structures, TOWER structures as level 2

L4 Finite element analysis of system of sections interconnected by full structure models
(sag-tension computations could range from minutes to hours depending on model)

Level 4 options

Limit level 4 modeling to PLS-POLE structures, TOWER structures as level 3

Limit level 4 modeling to guyed or otherwise asymmetrical structures

Strip joints/members that don't move significantly from level 4 TOWER models


Default Structure Attachment Stiffnesses for L2

The following default attachment stiffness values are used in calculations requiring a SAPS analysis. These values may be overridden on a attachment by attachment basis in Section/Modify.

	Transverse	Longitudinal
Dead ends	(lbs/ft) Fixed	Fixed
Non dead end with post insulator	(lbs/ft) Fixed	Fixed
Non dead end with non post insulator	(lbs/ft) Fixed	Fixed

[OK] [Cancel]

Only Insulators Swing (not brackets)



Use all adjustments

6) Finite Element Multiple Point Fit
Calculate catenary constant and required wire & insulator attachment points required to fit through three points in each span.
May change wire lengths, structure locations and display condition.

- Adjust wire length in each span to fit calculated catenary and wire attachment points
- Adjust structure stations, height and offset adjustments to match calculated insulator attachment points
- Follow up with a Finite Element All Spans Wire Length Adjustment (option 4) after adjustments above
- Least squares fit to all wire points within specified distance of 3 point catenary curve Max distance from 3 point (ft)
- Generate report showing attachment point locations and tensions
- Draw markers showing fit results (fit points, catenary curve, attachment points)
- Create survey points at calculated mid span and wire/insulator attachment points

Wire attach. feature

Insulator attach. feature

Mid span point feature

Feature code for structure points (may be used to help refine attachment point calculation)

Automatically select fit points in each span (for fit mode 4 and 6) Feature code for wire fit

- Use single point closest to current wire position (old way)
- Use centroid of all points within 1m of current wire position (tends to err on high side for bundles)
- Use center of rectangle encompassing all points within 1m of current wire position (good for bundles but sensitive to outliers)
- Use lowest of all points within 1m of current wire position (good for bundles but sensitive to outliers)
- Use center of smallest circle enclosing all points within 1 m of current wire (good for bundles but may be sensitive to outliers)
- Use bundle-aware centroid: centroid of each wire's centroids, using points within 1m of current position (less sensitive to outliers)



Enter either the bundle diameter : (in) or the bundle spacing : (in)

[Show Web technical note "Graphical Sag Options: Making the Wire System Match 'As-Built' Survey Points"](#)

Moved Structure

based on one phase only

bundle conductor located tower to centroid



Structure Modify

Structure #93
Line angle (deg) 14.31

16ext 28leg 5-4 bkt 2 cond

Station (ft) 41374.80
Height adjust. (ft) -32.60
Offset adjust. (ft) 0.00
Orientation (deg) 0

	Structure
1	93
2	C24 60
3	5'-4 angle bkt
4	
5	2gwde outside

Prev Next View Edit Material Google Ea

Structure Modify



Structure #93
Line angle (deg) 0.00

16ext 28leg 5-4 bkt 2 cond

Station (ft) 41373.99
Height adjust. (ft) -31.36
Offset adjust. (ft) 0.39
Orientation (deg) 7.157

	St
1	93
2	C24 60
3	5'-4 angle bk
4	
5	2gwde outside

Prev Next View Edit Material



Using FE6 adjust str
moved str of PI

FE6 first three options not selected

FE6 with first three options selected

Section Modify [?] [X]

Section 8 from structure #74B to structure #E216A

Type:

Voltage (kV): Conductors per phase:

Sagging

Override calculated ruling span

Condition:

Temperature (deg F):

Ruling Span (ft): Catenary (ft):

Horiz. Tension (lbs):

Display

Show selected weather case

WC: Wind from:

Condition: Phase:

CRI Notes: TVA Single Circuit

Displayed Phase will not take effect until override in Section/Display-Options is disabled.

SAPS Finite Element Sag-Tension Options

Clip Insulators (lock unstressed length, force finite element sag-tension)

Section Modify [?] [X]

Section 8 from structure #74B to structure #E216A

Type:

Voltage (kV): Conductors per phase:

Sagging

Override calculated ruling span

Condition:

Temperature (deg F):

Ruling Span (ft): Catenary (ft):

Horiz. Tension (lbs):

Display

Show selected weather case

WC: Wind from:

Condition: Phase:

CRI Notes: TVA Single Circuit

Displayed Phase will not take effect until override in Section/Display-Options is disabled.


SAPS Finite Element Sag-Tension Options

Clip Insulators (lock unstressed length, force finite element sag-tension)

Also

Longitudinal Loads on the structure will be determined from modeled insulator swings at As captured and sagging conditions

Str Loads FE3 wire adjustment As Capture



Str Loads FE3 wire adjustment 60deg Intial

Section 8 from structure #74B to structure #E216A

Type

Voltage (kV) Conductors per phase

Sagging

Override calculated ruling span

Ruling Span (ft)

Condition

Temperature (deg F)

Catenary (ft)

Horiz. Tension (lbs)

Struct 187, Set 1, Phase 1
Swing: T=-0.11 L=-1.86 (deg)
Loads: V=512 T=-1 L=-17 (lbs)

Struct 187, Set 2, Phase 1
Swing: T=-0.11 L=1.05 (deg)
Loads: V=512 T=-1 L=9 (lbs)


Struct 187, Set 3, Phase 1
Swing: T=-0.10 L=0.17 (deg)
Loads: V=2757 T=-5 L=8 (lbs)

Struct 187, Set 4, Phase 1
Swing: T=-0.10 L=1.01 (deg)
Loads: V=2757 T=-5 L=50 (lbs)

Struct 187, Set 5, Phase 1
Swing: T=-0.10 L=-0.23 (deg)
Loads: V=2758 T=-5 L=-11 (lbs)

(Click on section): Section #8, phase 1, 161kV, 'rail acsr 954 45_7', from Str. #74B Set 9 'Mahead' to Str. #E216A Set 4 'MID Back', All sections at BARE 60 'Initial RS', S=151552.54

Str Loads FE3 wire adjustment NESC 1" Ice 250D



Str Loads FE4 wire adjustment As Capture

Section Modify ? X

Section 8 from structure #74B to structure #E216A

Type

Voltage (kV) Conductors per phase

Sagging

Condition

Override calculated ruling span

Temperature (deg F)

Ruling Span (ft) Catenary (ft)

Horiz. Tension (lbs)

Display


Struct 187, Set 1, Phase 1
Swing: T=-0.10 L=1.24 (deg)
Loads: V=513 T=-1 L=11 (lbs)

Struct 187, Set 2, Phase 1
Swing: T=-0.10 L=3.82 (deg)
Loads: V=513 T=-1 L=34 (lbs)

Struct 187, Set 3, Phase 1
Swing: T=-0.08 L=1.39 (deg)
Loads: V=2764 T=-4 L=69 (lbs)

Struct 187, Set 4, Phase 1
Swing: T=-0.08 L=0.95 (deg)
Loads: V=2764 T=-4 L=49 (lbs)

Struct 187, Set 5, Phase 1
Swing: T=-0.08 L=1.40 (deg)
Loads: V=2764 T=-4 L=69 (lbs)



Str Loads FE4 wire adjustment 60deg Initial

Section Modify

Section 8 from structure #74B to structure #E216A

Type:


Voltage (kV): Conductors per phase:

Sagging

Override calculated ruling span

Ruling Span (ft): Condition: Temperature (deg F):

Catenary (ft): Horiz. Tension (lbs):



Structural Loads

- Longitudinal loads will depend on Sagging Conditions FE3 (Initial 60) FE4 (AS Captured Final)
- NESIC ICE (250D) loads will be influenced by As Capture Swing
- Additional Longitudinal Load created by Cut/Slide to provide clearances

Conclusion

- Assumption of insulators are plumb is removed by FE3 adjustment with correct sags in each span
- Results are still based on how well derive the conductor Temperature from weather data
- **Range** Ambient 66.1deg **to** No Wind 90.7deg
- Using all the weather data including solar radiation gave 71.2deg
- Thermal Rating is impacted approximately an equal temperature from the input conductor temperature
- Cost of additional modifications